



HAWK MEASUREMENT SYSTEMS

PTY. LTD. A.C.N. 006 782 449

15-17 MAURICE COURT
NUNAWADING VIC. 3131
P.O. BOX 286 NUNAWADING
VIC. 3131 AUSTRALIA
EMAIL: HawkSales@hawk.com.au
PH: +61-3 9873 4750
FAX: +61-3 9873 4538
(Sales/Engineering)
FAX: +61-3 9873 4384 (Accounts/Production)

DECLARATION OF CONFORMITY

Manufacturer's Name: HAWK MEASUREMENT SYSTEMS PTY LTD

Manufacturer's Address: 15-17 Maurice Court
Nunawading, Vic.
Australia 3131

declares that the product SULTAN Series Acoustic Wave Level Transmitter

Models AWI2, AWI234, AWR2, AWR234, AWRT, AWIH2, AWIH234, AWRH2,
AWRH234, AWRTH, AWSTHA, AWSTHB, AWSTHC and AWSTHD.

conform to the following product specifications:


Low Voltage Directive: 2004/108/EEC
EMC Directive: 2006/95/EEC
ATEX Directive: 94/9/EEC

Standards in whole or in part to which conformity is declared:

Normative Documents: EN 61326: 1997 +Amendment 1: 1998 + Amendment 2:2001
EN 61010-1:2001
EN 50014:1997 +Amendments 1 & 2:1999
EN 50020:2002
EN 50028:1987
EN 50281-1-1:1998
EN 50284:1999

Standards: IEC 1000-3-2: 1995 IEC 1000-4-4: 1995
IEC 1000-3-3: 1994 IEC 1000-4-5: 1995
IEC 1000-4-2: 1995 IEC 1000-4-6: 1996
IEC 1000-4-3: 1995 IEC 1000-4-11: 1994

Supplemental Information:

These products comply with the requirements of Low Voltage Directive 2004/108/EEC and EMC Directive 2006/95/EEC, and carry the CE-marking accordingly. Various models have been certified by Intertek under ATEX Directive 94/9/EC for operation in Category 1 & 2 hazardous gas and dust locations. All models are safe for operation in Category 3 hazardous gas and dust locations (Zones 2 & 22) with ATEX marking code  II 3GD IP67 T65°C.

Signature:

Name: Colin Prohasky
Position: Engineering Manager
Date: 18 January 2010
Place: Melbourne, Australia.